

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman Garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

To,

CH.RAGHUBIR SINGH MEMORIAL CONVENT SCHOOL
VILL. WARYAM KHERA TEH.ABOHAR DISTT FAZILKA


No.: Abohar/2627/00021 Dated : 17/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. LETTER NO.RSMWK/DIS/26-27/1 Dated: 16/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 16/04/2026. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report




Authorized Signatory
For, Block Water Testing Laboratory
Abohar



Principal

Ch. Raghubir Singh Memorial Convent School
VHL. WARYAM KHERA, Hakamabad Road
Tehsil Abohar, Distt. Fazilka-152116



Managing Director
Ch. Raghubir Singh Memorial
Convent School, Waryam Khera

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman Garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

TEST REPORT

Name & Address of Customer : CH.RAGHUBIR SINGH MEMORIAL CONVENT SCHOOL VILL. WARYAM KHERA TEH.ABOHAR DISTT FAZILKA		Customer Reference No.	No : LETTER NO.RSMWK/DIS/26-27/1 Dated : 16/04/2026
		Sample Submitted by	GAURAV KUMAR
		Date of Sample Receipt	16/04/2026
		Analysis Starting Date	16/04/2026
		Analysis completion Date	17/04/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:		Sample Type :	Treated Water
Test Report No.:	Abohar/2627/00021	Date of Issue :	17/04/2026
Registration no.:	Abohar/REG2627/00091	Condition of Sample :	Sealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	CH.RAGHUBIR SINGH MEMORIAL CONVENT SCHOOL(RO WATER) / NA
Village :	Waryam Khera	Habitation :	Waryam Khera
Block:	Abohar	District :	Fazilka
Latitude :	29.997156	Longitude:	74.0800568461

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.45@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	165	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	84	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	100	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	25.6	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	9	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	32	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Ashish Kumar
Sr. Chemist
Authorized Signatory
For,Block Water Testing Laboratory
Abohar


Principal

Ch. Raghubir Singh Memorial Convent School
VILL. WARYAM KHERA, Hakamabad Road
Tehsil Abohar, Distt. Fazilka-152116


Managing Director
Ch. Raghubir Singh Memorial
Convent School, Waryam Khera

End of the Test Report